



## FILL CERTIFICATE

PROJECT: Lot No 201 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_201

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 201 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



## FILL CERTIFICATE

PROJECT: Lot No 202 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_202

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 202 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



## FILL CERTIFICATE

PROJECT: Lot No 203 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_203

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 203 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



---

## FILL CERTIFICATE

PROJECT: Lot No 204 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_204

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 204 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



---

## FILL CERTIFICATE

PROJECT: Lot No 205 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_205

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 205 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



---

## FILL CERTIFICATE

PROJECT: Lot No 206 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_206

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 206 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



## FILL CERTIFICATE

PROJECT: Lot No 207 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_207

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 207 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



## FILL CERTIFICATE

PROJECT: Lot No 208 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_208

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 208 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a light blue circular stamp.

Nick Brock





---

## FILL CERTIFICATE

PROJECT: Lot No 209 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_209

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 209 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



## FILL CERTIFICATE

PROJECT: Lot No 210 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_210

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 210 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



---

**n**  
**FILL CERTIFICATE**

PROJECT: Lot No 211 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_211

DATE: 19 October 2017

---

**SUMMARY**

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 211 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

**LIMITATIONS**

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



## FILL CERTIFICATE

PROJECT: Lot No 212 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_212

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 212 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



## FILL CERTIFICATE

PROJECT: Lot No 213 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_213

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 213 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue horizontal line.

Nick Brock



## FILL CERTIFICATE

PROJECT: Lot No 214 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_214

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 214 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



---

## FILL CERTIFICATE

PROJECT: Lot No 215 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_215

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 215 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue horizontal line.

Nick Brock



---

## FILL CERTIFICATE

PROJECT: Lot No 216 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_216

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 216 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a light blue circular stamp.

Nick Brock





## FILL CERTIFICATE

PROJECT: Lot No 217 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_217

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 217 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a light blue horizontal line.

Nick Brock



---

## FILL CERTIFICATE

PROJECT: Lot No 218 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_218

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 218 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



---

## FILL CERTIFICATE

PROJECT: Lot No 219 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_219

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 219 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



## FILL CERTIFICATE

PROJECT: Lot No 220 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_220

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 220 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



## FILL CERTIFICATE

PROJECT: Lot No 221 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_221

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 221 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



---

## FILL CERTIFICATE

PROJECT: Lot No 222 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_222

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 222 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



## FILL CERTIFICATE

PROJECT: Lot No 223 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_223

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 223 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



---

## FILL CERTIFICATE

PROJECT: Lot No 224 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_224

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 224 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a light blue horizontal line.

Nick Brock





## FILL CERTIFICATE

PROJECT: Lot No 225 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_225

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 225 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



## FILL CERTIFICATE

PROJECT: Lot No 226 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_226

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 226 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



## FILL CERTIFICATE

PROJECT: Lot No 227 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_227

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 227 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



## FILL CERTIFICATE

PROJECT: Lot No 228 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_228

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 228 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



## FILL CERTIFICATE

PROJECT: Lot No 229 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_229

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 229 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



## FILL CERTIFICATE

PROJECT: Lot No 230 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_230

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 230 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



---

## FILL CERTIFICATE

PROJECT: Lot No 231 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_231

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 231 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



## FILL CERTIFICATE

PROJECT: Lot No 232 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_232

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 232 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue circular stamp.

Nick Brock





---

## FILL CERTIFICATE

PROJECT: Lot No 233 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_233

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 233 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



## FILL CERTIFICATE

PROJECT: Lot No 234 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_234

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 234 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



## FILL CERTIFICATE

PROJECT: Lot No 235 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_235

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 235 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



## FILL CERTIFICATE

PROJECT: Lot No 236 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_236

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 236 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



## FILL CERTIFICATE

PROJECT: Lot No 237 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_237

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 237 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



---

## FILL CERTIFICATE

PROJECT: Lot No 238 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_238

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 238 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



## FILL CERTIFICATE

PROJECT: Lot No 239 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_239

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 239 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



## FILL CERTIFICATE

PROJECT: Lot No 240 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_240

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 240 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a light blue circular stamp.

Nick Brock





---

## FILL CERTIFICATE

PROJECT: Lot No 241 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_241

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 241 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



---

## FILL CERTIFICATE

PROJECT: Lot No 242 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_242

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 242 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a light blue horizontal line.

Nick Brock



## FILL CERTIFICATE

PROJECT: Lot No 243 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_243

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 243 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



## FILL CERTIFICATE

PROJECT: Lot No 244 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_244

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 244 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



---

## FILL CERTIFICATE

PROJECT: Lot No 245 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_245

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 245 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



---

## FILL CERTIFICATE

PROJECT: Lot No 246 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_246

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 246 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue horizontal line.

Nick Brock



## FILL CERTIFICATE

PROJECT: Lot No 247 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_247

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 247 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



## FILL CERTIFICATE

PROJECT: Lot No 248 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_248

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 248 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue horizontal line.

Nick Brock





---

## FILL CERTIFICATE

PROJECT: Lot No 249 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_249

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 249 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



## FILL CERTIFICATE

PROJECT: Lot No 250 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_250

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 250 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



## FILL CERTIFICATE

PROJECT: Lot No 251 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_251

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 251 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



---

## FILL CERTIFICATE

PROJECT: Lot No 252 (as per Drawing No 303217CR200 E)  
Newhaven (Stage 2), Tarneit

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 17493\_252

DATE: 19 October 2017

---

## SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 252 of the Newhaven Estate (Stage 2), Tarneit in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

## LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15 September 2017.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a light blue horizontal line.

Nick Brock